



Garden State Laboratories, Inc.

Report Date: 10/06/2022

Bacteriological and Chemical Testing

Toll Free 800-273-8901
Telephone 908-688-8900
Fax 908-688-8966
Email: info@gsllabs.com
Internet: www.gsllabs.com

Main Lab
410 Hillside Avenue
Hillside, New Jersey 07205
NJDEP Lab Cert. #20044

Jersey Shore Lab
54 Main Street
Waretown, New Jersey 08758
NJDEP Lab Cert. #15037

Mathew Klein, M.S., Founder (1916-1996)
Harvey Klein, M.S., Laboratory Director
Jordan B. Klein, B.A., Exec. Vice President
Sharon Ercoliani, B.A. Laboratory Manager

For: Rahway Day Care Center Corp.
1071 New Brunswick Ave.

Rahway, NJ 07065

Laboratory Director:

Attention: Danielle Salley

Client Number: RAH05

Sample ID: Rahway Day Care Center -
1071 New Brunswick Ave.
Rahway, NJ 07065/Field
Blank

Lab Sample ID: 220927013-01

Site: Collection Date/Time: 09/23/2022 06:03

Matrix: Potable water Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Copper, Total Recoverable	EPA 200.7	1	< 0.0100 mg/l	1.3	0.0100	0.0021	20044	10/03/22 13:53	
Lead, Total Recoverable	EPA 200.9	1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	10/04/22 09:53	

Sample ID: Rahway Day Care Center -
1071 New Brunswick Ave.
Rahway, NJ 07065/Kitchen
Sink First Floor

Lab Sample ID: 220927013-02

Site: Collection Date/Time: 09/23/2022 06:06

Matrix: Potable water Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Copper, Total Recoverable	EPA 200.7	1	< 0.0100 mg/l	1.3	0.0100	0.0021	20044	10/03/22 13:57	
Lead, Total Recoverable	EPA 200.9	1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	10/04/22 10:01	



Sample ID:	Rahway Day Care Center - 1071 New Brunswick Ave. Rahway, NJ 07065/Water Fountain First Floor			Lab Sample ID:	220927013-03					
Site:				Collection Date/Time:	09/23/2022 06:15					
Matrix:	Potable water			Sample Type:	Grab					
Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers	
Copper, Total Recoverable	EPA 200.7	1	< 0.0100 mg/l	1.3	0.0100	0.0021	20044	10/03/22 14:02		
Lead, Total Recoverable	EPA 200.9	1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	10/04/22 10:04		

Sample ID:	Rahway Day Care Center - 1071 New Brunswick Ave. Rahway, NJ 07065/Boys Bathroom Sink First Floor			Lab Sample ID:	220927013-04					
Site:				Collection Date/Time:	09/23/2022 06:19					
Matrix:	Potable water			Sample Type:	Grab					
Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers	
Copper, Total Recoverable	EPA 200.7	1	< 0.0100 mg/l	1.3	0.0100	0.0021	20044	10/03/22 14:06		
Lead, Total Recoverable	EPA 200.9	1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	10/04/22 10:07		

Sample ID:	Rahway Day Care Center - 1071 New Brunswick Ave. Rahway, NJ 07065/Girls Bathroom Sink First Floor			Lab Sample ID:	220927013-05					
Site:				Collection Date/Time:	09/23/2022 06:27					
Matrix:	Potable water			Sample Type:	Grab					
Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers	
Copper, Total Recoverable	EPA 200.7	1	< 0.0100 mg/l	1.3	0.0100	0.0021	20044	10/03/22 14:10		
Lead, Total Recoverable	EPA 200.9	1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	10/04/22 10:10		

Sample ID:	Rahway Day Care Center - 1071 New Brunswick Ave. Rahway, NJ 07065/Classroom Bathroom Sink First Floor			Lab Sample ID:	220927013-06					
Site:				Collection Date/Time:	09/23/2022 06:36					
Matrix:	Potable water			Sample Type:	Grab					
Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers	
Copper, Total Recoverable	EPA 200.7	1	< 0.0100 mg/l	1.3	0.0100	0.0021	20044	10/03/22 14:29		
Lead, Total Recoverable	EPA 200.9	1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	10/04/22 10:13		



Sample ID: Rahway Day Care Center -
1071 New Brunswick Ave.
Rahway, NJ 07065/Water
Fountain Second Floor

Lab Sample ID: 220927013-07

Site: Collection Date/Time: 09/23/2022 06:48

Matrix: Potable water Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Copper, Total Recoverable	EPA 200.7	1	< 0.0100 mg/l	1.3	0.0100	0.0021	20044	10/03/22 14:34	
Lead, Total Recoverable	EPA 200.9	1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	10/04/22 10:16	

Sample ID: Rahway Day Care Center -
1071 New Brunswick Ave.
Rahway, NJ 07065/Bathroom
Sink Second floor

Lab Sample ID: 220927013-08

Site: Collection Date/Time: 09/23/2022 06:55

Matrix: Potable water Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Copper, Total Recoverable	EPA 200.7	1	< 0.0100 mg/l	1.3	0.0100	0.0021	20044	10/03/22 14:38	
Lead, Total Recoverable	EPA 200.9	1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	10/04/22 11:39	

*DF=Dilution factor, <=less than, MCL=Maximum Contaminant Level, Rep. Limit=Reporting Limit and MDL=Method Detection Limit.
The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.
When sample is collected by Garden State Labs, it is taken in accordance with the most current Field Sampling Plan GSL.FS.
Main Lab certified by NJDEP #20044-TNI, NY Dept. of Health #11550 and PADEP #68-03680.*

